



## RL2/A

---

Room air quality sensor for mixed gas (VOC) with LED display

Measuring size: VOC

Output: 0-10 V, 4-20 mA, Relay

Highlights: LED-Display



### Description

The RL2/A mixed gas sensor with LED display registers the air quality in the range of 0...100% with respect to the calibration gas and converts the measured values into a linear output signal 0-10 V respectively 4-20 mA. As an option the air quality sensor has a potential-free changeover contact.

The sensitivity VOC can be set on the device at ?low?, ?medium? and ?high?.

The air quality that is defined as normal for the environment can be specified on initial start-up by manual calibration on the device (zero point balance). The air quality sensor performs an automatic calibration at regular intervals, long-term drifts and the operational wear of the sensor element are thus totally eliminated.



## Technical Specifications

Measurement range VOC	0-100% (good / bad air quality, referring to the calibration gas)
Accuracy	±15% FS
Running-in time	1 h
Response time (t90)	max. 60 s
Long term stability	< 15% FS/year at norm load
Sensor	metal oxide VOC-sensor
Sensor protection	mounted inside housing
Supply voltage	24 V AC/DC (±5%)
Current consumption	max. 60 mA
Analogue output 0-10 V	3-wire connection, min. load resistance 100 kOhm
Analogue output 4-20 mA	3-wire connection, max. $R_{Load}(Ohm) = (+U_b - 15 V) / 0,02 A$
Alarm output	1 x potential-free change-over contact, 48 V, 1 A
Switching Hysteresis Relay	2% FS (without Display), 0,5...5% FS adjustable (with Display)
Equipment	LED display: 1-3 green (good), 4-7 yellow (average), 8-10 red (bad)
Electrical connection	screw terminals max. 1,5 mm <sup>2</sup>
Housing	ABS polyman, colour signal white like RAL 9003
Cable gland	on the back or housing side (predetermined breaking point)
Dimensions	Housing: L 82 x W 82 x H 25 mm
Weight	ca. 70 g
Protection type	IP30
Protection class	III
Working range r.H.	0...98% r.H. in contaminant-free, non-condensing air
Working temperature	0...+50°C
Storage temperature	-20...+50°C
Initial operation	After switch-on of the device follows a self-test and the tempering, which takes ca. 1 h depending on the environmental conditions. At this time the analogue output drifts from the actual measurement value.
Automatic calibration	The automatic VOC calibration takes place every 7 days, this compensates for any drifts and achieves excellent long-term stability. To ensure this function, the device must be supplied with power for at least 7 days without interruption and ventilated with fresh air once for approx. 10 minutes within this period. The automatic calibration can be deactivated if necessary and performed manually.
Manual calibration	The manual VOC calibration of the output signal to 1V (zero point) is started by pressing the button on the circuit board (hold down for approx. 5 seconds until the LED flashes). Before that, continuous operation of min. 2 hours with air defined as normal air quality. The LED is deactivated after successful calibration.
Installation	on-wall or on flush-mounted box
Approvals	CE, EAC, RoHS



## Variants

Article Number		
Supply voltage	Output VOC	Version
RL2/A-UI		
24 V AC/DC	0-10 V, 4-20 mA	LED display
RL2/A-UIR		
24 V AC/DC	0-10 V, 4-20 mA, changer	LED display

## Accessories

---

SB/E

Snap-on mounting for DIN rails





### Dimensional Drawing

